

Indoor & Outdoor Climate

The moderate climate during the first half of the contest were favourable to operate the building with shading and natural ventilation only. The yellow bars indicate the temperature range for receiving full points (23°C to 25°C). The interruptions mark the times for the – not scored - public tours, where indoor temperatures reach outdoor conditions due to intensive natural ventilation. The last four days with temperatures up to 36°C create strong needs for active cooling. The installed capacity was not fully sufficient to quickly reduce the high indoor temperatures after the public tours.

